



**Report For:** KJ Trade and Production Joint Stock Company  
587 Arc En Ciel  
Orleans, Ontario  
K4A 3J1  
Phone: 819-329-4950  
Email: tloan.nguyen@importexportvncan.ca

**Laboratory #:** 845518-2-20  
**Report Date:** October 13, 2020  
**Received Date:** September 30, 2020  
**FINAL**

**Attention:** Thanh Loan Nguyen  
**Specimen:** #2: KJ Mask. Model: KJVINA.05. Lot: 200605

## TEST REPORT

One specimen, consisting of Medical Masks, was submitted to be tested for bacteria filtration efficiency, differential pressure, particle filtration efficiency, synthetic blood penetration and flame spread to determine acceptability with level barrier classification under ASTM F2100-19 requirements.

### Medical Face Mask Material Requirements

Characteristic	Level 1 Barrier	Level 2 Barrier	Level 3 Barrier	Summary Results
Bacterial Filtration Efficiency, %	≥95	≥98	≥98	Pass any Level
Differential Pressure, mm H <sub>2</sub> O/cm <sup>2</sup>	<5.0	<6.0	<6.0	Pass Level 2 & 3
Sub-Micron Particulate Filtration Efficiency at 0.1 micron, %	≥95	≥98	≥98	Pass any Level
Synthetic Blood Penetration minimum pressure in mmHg for pass result	80	120	160	Pass Level 3
Flame Spread	Class 1	Class 1	Class 1	Pass any Level
<b>OVERALL PERFORMANCE LEVEL</b>	<b>Complete - Level 3</b>			

This report is subject to the following terms and conditions: 1. This report relates only to the specimen provided and there is no representation or warranty that it applies to similar substances or materials or the bulk of which the specimen is a part. 2. The content of this report is for the information of the customer identified above only and it shall not be reprinted, published or disclosed to any other party except in full. Prior written consent from Cambridge Materials Testing Limited is required. 3. The name Cambridge Materials Testing Limited shall not be used in connection with the specimen reported on or any substance or materials similar to that specimen without the prior written consent of Cambridge Materials Testing Limited. 4. Neither Cambridge Materials Testing Limited nor any of its employees shall be responsible or held liable for any claims, loss or damages arising in consequence of reliance on this report or any default, error or omission in its preparation or the tests conducted. 5. Specimens are retained 6 months, test reports and test data are retained 7 years from date of final test report and then disposed of, unless instructed otherwise in writing. 6. When making a statement of conformity to a specification or standard the report will make the statement of conformity based on the absolute value of the test result. Test Report Template Revision August 20, 2019



Laboratory # 845518-2-20

**FINAL**

KJ Trade and Production Joint Stock Company

**DIFFERENTIAL PRESSURE**

EN 14683:2019 edition Annex C

Each specimen was conditioned for 4 hours minimum at 21+/-5 C and 85+/-5 % R.H.

Requirements ASTM F2100-19:

Differential Pressure (mmH<sub>2</sub>O/cm<sup>2</sup>)

Level 1 Barrier: <5.0

Level 2 Barrier: <6.0

Level 3 Barrier: <6.0

**RESULTS**

<u>Specimen ID</u>	<u>Area ID</u>	<u>Differential Pressure (mmH<sub>2</sub>O/cm<sup>2</sup>)</u>	<u>Specimen Pass/Fail</u>	<u>FINAL RESULT</u>
2-1	1	4.7	PASS	PASS Level 2 & 3
	2	5.1		
	3	5.5		
	4	4.0		
	5	5.5		
	AVERAGE	5.0		
2-2	1	6.1	PASS	
	2	5.6		
	3	4.7		
	4	5.6		
	5	5.0		
	AVERAGE	5.4		
2-3	1	4.1	PASS	
	2	4.6		
	3	4.0		
	4	4.6		
	5	4.8		
	AVERAGE	4.4		
2-4	1	4.6	PASS	
	2	4.4		
	3	4.6		
	4	4.9		
	5	4.4		
	AVERAGE	4.5		
2-5	1	5.2	PASS	
	2	4.5		
	3	5.4		
	4	4.6		
	5	5.0		
	AVERAGE	4.9		

Mask Surface Area: 25mm diameter (x5 test areas) (4.9 cm<sup>2</sup>)

Air Flow Rate: 8 L/min

Mask Location Specimen taken from: 5 Areas from each specimen distributed all surface wide

Note: For a test plan of 5 specimens, no failure is allowed for an Acceptable Quality Limit of 4.0%.



Laboratory # 845518-2-20

**FINAL**

KJ Trade and Production Joint Stock Company

**SYNTHETIC BLOOD PENETRATION**

ASTM F1862/F1862M-17 at 160 mmHg pressure

**RESULTS**

Specimen #	Test Pressure (mmHg)	Total Number of Specimens	Number of Pass Specimens	<b>FINAL RESULT</b>
2	160	32	29	<b>Pass for Level 3</b>

Note: Acceptable Quality Limit of 4.0% is met for single sampling plan when 29 or more of the 32 tested specimens show pass results.

<b>Material construction type</b>	Not provided/unknown
<b>Supplier</b>	KJ VINA TRADE AND PRODUCTION JSC
<b>Lot number</b>	200605
<b>Date of receipt</b>	September 30, 2020
<b>Date of test</b>	October 2, 2020
<b>Fluid velocity (cm/s)</b>	635
<b>Volume of impact fluid (ml)</b>	2
<b>Angle of pneumatic valve to horizontal</b>	2°
<b>Description target area mask</b>	Blue ripple area
<b>Distance from tip cannula to mask (in)</b>	12
<b>Technique to enhance visual detection</b>	Cotton swab used to lightly daub on the surface
<b>Conditioning parameters</b>	21±5°C, 85±5% R.H for minimum of 4 hours



Laboratory # 845518-2-20

**FINAL**

KJ Trade and Production Joint Stock Company

**FLAME SPREAD**

The specimen, consisting of 5 masks, was tested in accordance to 16 CFR 1610 (1-1-16 Edition).

	Specimen #	RESULT	CONCLUSION
<b>Specimen #2</b>	2-1	IBE	<b>Classified as Class 1 PASS for ANY LEVEL</b>
	2-2	IBE	
	2-3	IBE	
	2-4	IBE	
	2-5	IBE	

**IBE:** Ignited but extinguished

**Test:** Flame Resistance 45° angle test. One-Second Flame Impingement.  
**Type of fabric:** Without a raised fiber surface  
**Surface tested:** Face  
**Type of test:** Original State  
**Direction tested:** Length  
**Testing Conditioning:** Specimens conditioned at 105°C for 30 min, then placed in desiccator  
**Requirements:** The flame spread time for textile products without a raised fibre surface must be greater than 3.5 seconds.

Note: For a test plan of 5 specimens, no failure is allowed for an Acceptable Quality Limit of 4.0%.



Laboratory # 845518-2-20

**FINAL**

KJ Trade and Production Joint Stock Company

**Particle Filtration Efficiency**

Particles: Monodispersed polystyrene latex spheres (PSL)

Particles Counter: TSI scanning mobility particle sizer spectrometer 3082 and CPC

Tested as per ASTM F2299, non-neutralized aerosol challenge measured over 3 minutes (test specimen / control counts before and after test specimen and averaged)

Test Side: Inside

Area Tested: 21.7 cm<sup>2</sup>

Particle Size: 0.1 µm

Laboratory Conditions: 23°C, 54% relative humidity (RH)

Requirements ASTM F2100-19:

Particle filtration efficiency at 0.1 micron (%)

Level 1 Barrier: ≥95


Level 2 Barrier: ≥98

Level 3 Barrier: ≥98

**RESULTS**

Specimen #	Average Control Counts	Specimen Counts	Filtration Efficiency (%)	Specimen (Pass/Fail)	FINAL RESULT
2-1	80,572	868	99	Pass	<b>Pass any Level</b>
2-2	78,407	1,553	98	Pass	
2-3	85,768	1,923	98	Pass	
2-4	81,062	564	99	Pass	
2-5	80,069	512	99	Pass	

Note: The PFE equipment was outsourced and located at University of Toronto, 223 College Street, Toronto, ON M5T 1R4.



Laboratory # 845518-2-20

**FINAL**

KJ Trade and Production Joint Stock Company

**Bacterial Filtration Efficiency**

A Bacterial Filtration Efficiency (BFE) test was completed according to the procedure in ASTM F2101-19 to determine the filtration efficiency of test articles by comparing the bacterial control counts upstream of the test article to the bacterial counts recovered downstream. A suspension of *S. aureus* was aerosolized using a nebulizer and delivered to the test article at a constant rate with a target delivery rate of  $1.7 \times 10^3 - 3.0 \times 10^3$  colony forming units (CFU) per test article with a mean particle size of  $3.0 \pm 0.3 \mu\text{m}$ . The aerosolized suspension was drawn through the test article which was clamped in a six stage Andersen air sampler, at a constant flow rate of 28.3 liters per minute (LPM), for collection on bacteriological agar plates.

Challenge Microbe: *Staphylococcus aureus* ATCC 6538  
Test Side: User side facing challenge  
Area Tested:  $\sim 38.5 \text{ cm}^2$   
Flow Rate: 28.3 LPM  
Test Article Conditioning:  $85 \pm 5\% \text{ RH}$  at  $25.0 \pm 0.5^\circ\text{C}$  for a minimum of 4 hours  
Challenge Level:  $2.347 \times 10^3 \text{ CFU}$   
Mean Particle Size:  $3.17 \mu\text{m}$

Requirements ASTM F2100-19:

Bacterial filtration efficiency (%)  
Level 1 Barrier:  $\geq 95$   
Level 2 Barrier:  $\geq 98$   
Level 3 Barrier:  $\geq 98$

**RESULTS**

Specimen #	Total CFU Recovered	Percent BFE (%)	Specimen (Pass/Fail)	FINAL RESULT
1-1	0	>99.9	Pass	<b>Pass any Level</b>
1-2	0	>99.9	Pass	
1-3	0	>99.9	Pass	

The filtration efficiency percentages were calculated using the following equation:

$$\% \text{ BFE} = \frac{C - T}{C} \times 100$$

C = Challenge Level  
T = Total CFU recovered downstream of test article

Note: Testing performed by GAP EnviroMicrobial Services Ltd., 1020 Hargrieve Road, Unit 14, London, Ontario, Canada, N6E 1P5